



2010 MAY 1 1 PM 1: 58

11117 Mockingbird Drive Omaha, Nebraska 68137 www.atcassociates.com

Phone: 402.697.9747 Fax: 402.697.9170

April 9, 2010

Tennessee Dept. of Environment & Conservation Div. of Air Pollution Control 9th Floor, L&C Annex 401 Church Street Nashville, TN 37243-1531

RE: U.S. Cellular® - Emergency Generator Air Permit Applications

Dear Sir or Madam:

ATC Associates, Inc. was retained by U.S. Cellular® to complete air permit applications for their emergency generators within the State of Tennessee pursuant to APC Rule Ch. 1200. Upon review of U.S. Cellular's databases and through confirmation with their Network Field Engineers, ATC determined that U.S. Cellular currently has fifteen (15) generators within the State of Tennessee that are required to obtain air permits.

Attached are the Air Permit Application Forms (Form APC20, Form APC21&24 and APC22) for the fifteen (15) generators along with a check in the amount of \$1,500.00 (\$100.00/facility) for the permit fees. Also attached is a list of the fifteen (15) facilities with generators.

If you should have any questions, please do not hesitate to call me at (515) 981-3216.

Sincerely,

ATC ASSOCIATES INC.

Mike Freese, REM

Sr. Project Manager

Attachments

cc: Doug Zabrin – U.S. Cellular[®]
Brad Summers – U.S. Cellular[®]
Dale Mattson – U.S. Cellular[®]
Jerry Williams – U.S. Cellular[®]
Mark Clark – U.S. Cellular[®]
Tony Chandler – U.S. Cellular[®]

Permit Required Facilities


Site #	Site Name	Site Address	Site City	Site State	Site Zip	Site County	Site Contact	Contact Phone	Gen. Mfr.	Gen, Model	Gen. Size (KW)	Generator Fuel Type
	411316 RATTLESNAKE										3	DSL -
411316		347 Tower Road	Gatlinburg	TN	37738	Sevier	Brad Summers	865.705.7600	Cummins	DGGD	35	Diesel
860327	860327 HARTSVILLE	136 Morrison Street	Hartsville	TN	37074	Trousdale	Dale Mattson	Not Listed	Kohler	50REOZJC		DSL - Diesel
			Red Boiling Springs	ΤN	37150	Macon	Dale Mattson	Not Listed	Kohler	50REOZJC		DSL - Diesel
		461 Green Grove	Lafayette	TN	t		Dale Mattson	Not Listed	Kohler	50REOZJC	37	DSL - Diesel
860319	860319 PIONEER	8638 Sticking Creek Rd.	Pioneer	TN	37847	Campbell	Jerry Williams	865.679.4446	Kohler	50REOZJC	37	DSL - Diesel
860348	860348 PEAVINE	653 Eroh Rd.	Crossville	TN	38571	Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860359	860359 ROBBINS		Robbins	TN	37852	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - Diesel
860362	860362 PINEY	252 Old Harriman Hwy.	Harriman	TN	37748	Roane	Mike Clark	931.979.0041	Kohier	50REOZJC	37	DSL - Diesel
860367	860367 CORDELL	8787 James Baker Highway	Huntsville	TN	37756	Scott	Mike Clark	931.979.0041	Kohler	50REOZJC	37	DSL - 7 Diesel
860368	860368 MOFFIT	4496 Straight Fork Road	Pioneer	TN	37847	Scott	Mike Clark	931.979.0041	Kohler	30REOZJC	27	DSL - 7 Diesel
860381	860381 STEPHENS	180 Tree Top Lane	Coalfield	TN	37719	Morgan	Mike Clark	931,979,0041	Kohler	50REOZJC	37	DSL - 7 Diesel
411346	411346 DOUGLAS DAN	1443 Holbert Road	Dandridge	TN	3772	Sevier	Tony Chandler	865.679.0010	Kohler	50REOZJC	3)	DSL - 7 Diesel
860354	860354 CRAB ORCHARD	384 Godsey Road	Crab Orchard	TN	3772	Cumberland	Mike Clark	931.979.0041	Kohler	30REOZJC	27	DSL - 7 Diesei
860358	860358 GLEN MARY	593 Huckelby Road	Robbins	TN	37852	Scott	Mike Clark	931,979.0041	Kohler	50REOZJC	31	DSL - 7 Diesel
860345	860345 TANSI	490Vandiver Rd.	Crossville	TN	3857	l Cumberland	Mike Clark	931.979.0041	Kohler	50REOZJC	3	DSL - 7 Diesel

0860	05/06/2010	R 0000199	217	1500009260	
INVOICE NUMBER	DATE	AMOUNT	DISCOUNT	NET AMOUNT	
050510 AIR PERMIT FEES	05/05/2010	2010 MAY 1 1 1	PH 1: 58	\$1,500.00	
Tennessee RSA No. 3 LP 8410 W Bryn Mawr Ave Suite 700 Chicago, IL 60631-3415					

 $\hat{\beta}^{(i)}_{X} :$

Tennessee RSA No. 3 LP 8410 W Bryn Mawr Ave Suite 700 Chicago, IL 60631-3415

6.13



BANK OF AMERICA

2-3 710 IL

May 06, 2010

0860 0000199217

One thousand five hundred and 00/100 Dollars

ORDER


State of Tennessee Dept of Environment - Conservation 401 Church Street NASHVILLE TN 37243

REMOVE CUCUMENT ALONG THE PERFORATION

\$1,500.00 ONLY VOID IF NOT CASHED WITHIN 180 DAYS OF ISSUE

#1500009260# #071000039# 5800963430#

Remove this stub before cashing. Fold, crease, and tear along perforation.



. U.S. Cellular.

State of Tennessee Dept of Environment - Conservation 401 Church Street NASHVILLE TN 37243

Call 1-800-PICK-UPS° (1-800-742-5877) or visit ups.com^o

ing services:

- containing letters, business correspondence, urgent documents, and electronic media. When a UPS Next Day Air service is selected, UPS Express Envelopes containing items other than those listed above are subject to the corresponding rates for the applicable weight For UPS Next Day Air services, there is no weight limit for envelopes
- Express Envelopes are not recommended for shipments of electronic media containing sensitive personal information.
- For UPS Worldwide Express, the UPS Express Envelope may be used only for documents of no commercial value. There is no limit on the weight or number of pages you can enclose.
- Do not use UPS 2nd Day Air services to send letters weighing over
 13 ounces in this envelope. For UPS 2nd Day Air services, UPS Express Envelopes weighing one pound or more are subject to the corresponding

Regal Site

Son theory laborated the Algorithm is Body a pripar with the many the artist part and the first ASSES 在 医骨髓 医多种斑疹 医 医 医电子 医医性性 医乳管 医乳

Decision Green™

our pursuit of sustainable business practices worldwide. For example, this envelope is made from 100% recycled material and is both reusable and recyclable. Decision Green is UPS's environmental platform, reflecting



SHIP TO:
TENNESSEE DEPT OF ENVIRONMENTAL DIV OF AIR POLLUTION CONTROL
OTH FLOOR L&C ANNEX
401 CHERCH ST.
NASHVILLE TN 37219-2310 Cost Center: 175105 BILLING: P/P PATRICE GOODWIN
773-399-8999
US CELLIUM-CORPORATE
8410 W BRYH MAWR AVENUE
CHICACO IL 60631 TRACKING #: 1Z 61X 045 02 9859 4810 UPS 2ND DAY AIR 2 LBS 9-02 1 OF 1 OPS CampusShip: Lab

Page 1 of 2

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone: (615) 532-0554 FAX: (615) 532-0614

2010 MAY 1 1 PM 1: 58

PERMIT APPLICATION

APC 20

LEASE TYPE OR P	RINT AND SUBMIT	IN DUPLICATE FO	R EACH EMISS	ION SO	URCE. ATTACH APPROPRIATE SOURCE
ESCRIPTION FOR					AND GOLD HAND DON'T NO
ORGANIZATION	N'S LEGAL NAME		/// FOR	APC COMPANYPOINT NO.	
S Cellular					APC LOG/PERMIT NO.
. MAILING ADDR	ESS (ST/RD/P.O. BOX)		/// APC	APC LOG/PERMIT NO.
410 W. Bryn Mawr Av	enue, Suite 900	T are t man	am cone	/ ., ·	DUONE WITH A DEA CODE
CITY Chicago		STATE	ZIP CODE		PHONE WITH AREA CODE 773-399-6899
-		Illinois	60631		PHONE WITH AREA CODE
. PRINCIPAL TEC	CHNICAL CONTACT				
ohn Glatz/US Cellular	Mike Freese/ATC As	sociates			773-399-6899 515-981-3216 COUNTY NAME
. SITE ADDRESS	,				
	ad (Site known as 8603		2400		Campbell PHONE WITH AREA CODE
CITY OR DISTAN	NCE TO NEAREST TO	WN	ZIP CODE 37847		865-679-4446 Jerry Williams – Network Field Eng.
ioneer				***	
. EMISSION SOUP IDENTIFIES THIS	RCE NO. (NUMBER W S SOURCE)	HICH UNIQUELY	PERMIT RENEV	VAL NO(X))
S-1	·				
. BRIEF DESCRIP	TION OF EMISSION	SOURCE			
ackup Emergency Gen	erator (Kohler Model 5	OREOZJC)			
, ,	`	OREOZJC)			
. TYPE OF PERM	`	COMPLETION	LAST PERMIT		EMISSION SOURCE REFERENCE NUMBER
. TYPE OF PERM	IT REQUESTED	COMPLETION DATE		1,000	
CONSTRUCTION (X) OPERATING	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED	COMPLETION			EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X)	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRU-	COMPLETION DATE	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER		
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER ()	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE	COMPLETION DATE DATE COMPLETED	NUMBER LAST PERMIT NUMBER LAST PERMIT		EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE	COMPLETION DATE DATE COMPLETED	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER		EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE AST LOCATION	COMPLETION DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER		EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PE	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE AST LOCATION INGES THAT HAVE INTERMIT APPLICATION	COMPLETION DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT OF	R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PE	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE AST LOCATION INGES THAT HAVE INTERMIT APPLICATION	COMPLETION DATE DATE COMPLETED BEEN MADE TO THIS	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT OF	R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER
CONSTRUCTION (X) OPERATING (X) LOCATION TRANSFER () ADDRESS OF LA OPERATING PE	IT REQUESTED STARTING DATE Installed 2/10 DATE CONSTRUCTION STARTED Installed 2/10 TRANSFER DATE AST LOCATION INGES THAT HAVE INTERMIT APPLICATION PPLICATION MUST B	COMPLETION DATE DATE COMPLETED BEEN MADE TO THIS SIGNED BEFORE IT	NUMBER LAST PERMIT NUMBER LAST PERMIT NUMBER EQUIPMENT OF	R OPER	EMISSION SOURCE REFERENCE NUMBER EMISSION SOURCE REFERENCE NUMBER ATION SINCE THE LAST CONSTRUCTION OR DATE PHONE WITH AREA CODE 4/30/10

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone:(615) 532-0554 FAX: (615) 532-0614

2010 MAY 1 1 PM 1: 58

PROCESS OR FUEL BURNING SOURCE DESCRIPTION

APC21(& 24)

PLEASE TYPE OR PRINT, SUBMI	T IN DUPLICAT	TE AND .	АТТАСН ТО ТН	E PERMIT A	PPLICA	ATIC	N.	
1. ORGANIZATION NAME	AP	C COMPANY-POINT NO.						
US Cellular	FOR							
2. EMISSION SOURCE NO. (AS O	111	AP	C PERMIT/LOG NO.					
ES-1				4812	APC			
3. DESCRIPTION OF PROCESS OR	FUEL BURNING	G UNIT						
Backup Emergency Generator (Kohler M	odel 50REOZJC)							
	,							
4. NORMAL OPERATION:	HOURS/DAY	DAYS/	WEEK	WEEKS/YE	AR	DA	YS/YEAR	
→ Emergency generator is exercised on a periodic basis								
5. PERCENT ANNUAL	DECFEB.	MARCI	I-MAY	JUNE-AUG.		SE	PTNOV.	
THROUGHPUT: →	25%		25%	25%			25%	
6. TYPE OF PERMIT APPLICATIO		<u> </u>	4.9.70	4370		10	HECK BELOW ONE ONLY)	
PROCESS SOURCE: APPLY FOR	A SEPARATE PE			(CHECK A	Γ	<u> </u>		
RIGHT, AND CON				NY CONTRACT				
PROCESS SOURCE WITH IN-P MATERIALS HEA			IS OF COMBUSTIC ARATE PERMIT FO				()	
(CHECK AT RIG	HT, AND COMPL	ETE LINE	S 7, 8, AND 10 THE	OUGH 14)		<u> </u>		
NON-PROCESS FUEL BURNIN			OF COMBUSTION ORM FOR EACH B			(X)		
			ORM FOR EACH BOOM				(,,)	
			ND COMPLETE LI					
7. TYPE OF OPERATION: CONTI	NUOUS,	BA	ТСН	NORMAL E	BATCH	NORMAL BATCHES/DAY		
()	(<u> </u>	1 11711.				
8. PROCESS MATERIAL INPUTS A		RAM*		S (POUNDS/HOUR)			(FOR APC USE ONLY)	
IN-PROCESS SOLID FUELS A.	REFE	RENCE	DESIGN	ACTU	AL	/	SCC CODE	
<i>33</i> .						1		
В,						7		
						7		
C.		······································				7		
						7		
D.						1		
E.		***************************************				1,		
						/		
F.						/		
				ļ		<u> </u>		
G.						1		
						 		
	TOT	ALS				/		
			1	1		1		

^{*} A SIMPLE PROCESS FLOW DIAGRAM MUST BE ATTACHED.

9,	ROILER O	R BURNER DA	TA: (COMPLETE LI	NES 9 TO 14 U	SING A SEPAI	RATE FO	RM FOR	EAC	H BOILER)	
<i>7</i> ,	BOILER	STACK	TYPE OF FIRING***		RATED BO	ILER	RATED I	NPUT	OTHER BOILE	
	NUMBER	NUMBER**			HORSEPOV		CAPACI (10 ⁶ BTU		(SPECIFY CAP	ACITY AND UNITS)
	ES-1	EP-1				(37 kilowatt		
BOILER SERIAL NO. DATE CONSTRUCTED						AST MO	DIFICAT	TION (EXPLAIN IN COMM	MENTS BELOW).
225	8139		February 2009		NA				·····	
** BOILERS WITH A COMMON STACK WILL HAVE THE SAME STACK NUMBER. *** CYCLONE, SPREADER (WITH OR WITHOUT REINJECTION), PULVERIZED (WET OR DRY BOT REINJECTION), OTHER STOKER (SPECIFY TYPE), HAND FIRED, AUTOMATIC, OR OTHER TYI IN COMMENTS).							TYPE (DESCRIBE I	BELOW		
10.			TE FOR A PROCESS SO	OURCE WITH	IN-PROCESS I					IG SOURCE)
	PRIMARY	FUEL TYPE (S	PECIFY) Diesel Fuel			STANI	OBY FUE	LTYI	PE(S)(SPECIFY)	
	FUELS US	ED	ANNUAL USAGE	HOURLY	YUSAGE	%	<u> </u>	%	BTU VALUE	(FOR APC ONLY)
				DESIGN	AVERAGE	SULF	UR A	SH	OF FUEL	SCC CODE
********	NATURAL	GAS:	10 ⁶ CUFT	CUFT	CUFT	111		/		
	#2 FUEL O	IL: Diesel Fuel	10 ³ GAL	GAL:4.3	GAL: 3.6		1			
			<100 gal./year	gal./hr. @ full standby	gal./hr. @ full prime	<0.5	1	1	140,000/gal.	20200102
	#5 FUEL O	IL:	10 ³ GAL	GAL	GAL		1	/		
	#6 FUEL O	IL:	10 ³ GAL	GAL	GAL		//	/		
	COAL:		TONS	LBS	LBS					
	WOOD:		TONS	LBS	LBS	/ / /	/ /	/		
	LIQUID PF	ROPANE:	10 ³ GAL	GAL	GAL	111	/ / / /	/		
	OTHER (.S TYPE & U							,		
11.	IF WOOD	IS USED AS A	L FUEL, SPECIFY TY	PES AND EST	I IMATE PERC	ENT BY	WEIGH	T OF	BARK	
12.	IF WOOD	IS USED WITE	OTHER FUELS, SP	ECIFY PERCI	ENT BY WEIG	HT OF	WOOD C	HAR	GED TO THE BUR	NER.
13,	COMMEN	ITS: Dynass Fis	ow Diagram below.							
13.	COMMEN	i i si i i ucess i ie	w Diagram below.		ÆÞ-	-1				
					1					
	Electricity									
	ES-1 Emer. Gen.									
					T Diesel Fuel A	ST				
1.4	SIGNATU	DE -		A 3					<u></u>	DATE
14	SIGNATU	Le	hull	West	1					4/30/2010
			· //							

NOT TO BE USED FOR TITLE V APPLICATIONS



9th Floor, L & C Annex 401 Church Street Nashville, TN 37243-1531 Telephone: (615) 532-0554 FAX: (615) 532-0614

2010 MAY 1 1 PM 1: 58

EMISSION POINT DESCRIPTION

APC 22

1. ORGANIZATION NAME	· ·				111	APC COMPA	NY POINT NO.	
US Cellular		THE COMPLETE FOR THE						
2. EMISSION SOURCE NO	FOR	FOR APC SEQUENCE NO.						
	· (1 KOM ALT	acation	FLOW DIAGRAM PO	**** **********				
ES-1	T		EP-1	T VIAN I VIII VIII VIII VIII VIII VIII VI	APC	*****	33 VII 4 V	
3. LOCATION:	LATITUDE		LONGITUDE	UTM VERTICAL		UTM HORIZO	UNTAL	
~→	36.427739		-84302230					
4. BRIEF EMISSION POIN	T DESCRIPTI	ON (ATTACH A	A SKETCH IF APPROPI	RIATE):		DISTANCE T PROPERTY 1		
Exhaust for emergency generate	or					FROFERIII	TIME (L1)	
						On mountain t	ор	
COMPLETE LINES 5 AND 6	IE DIEEEDENT	PAUT MOGE	ON THE DROCESS OF I	CHEL BHDMING COLL	DCE DESCRIPTIO	NI (APC 21)		
5. NORMAL	HOURS/DAY		DAYS/WEEK	WEEK/YEAR	KUE DEBUKIT IKO	DAYS/YEAR		
OPERATION:			~	., and a diffit		~ 1 * * * * * * * * * * * * * * * * * *		
	Emergency ge exercised on	enerator is						
6. PERCENT ANNUAL	DECFEB.	a perroure	MARCH-MAY	JUNE-AUG.		SEPTNOV.		
THROUGHPUT:								
	HEIGHT AB	5%	25%	25%			25%	
7. STACK OR EMISSION POINT DATA:	GRADE (F		DIAMETER (FT)	TEMPERATURE (°F)	% OF TIME OVER 125°F	DIRECTION (UP, DOWN (
	, ,		, ,			HORIZONTAL)		
→ DATA AT EVIT	~5'	Y 1 A T	0,2	1066 ' MOISTURE		Vertical MOISTURE		
DATA AT EXIT CONDITIONS:	FLOW (ACTUAL FT ³ /MIN,)		VELOCITY (FT/SEC)	(GRAINS/FT³)		(PERCENT)		
						,		
DATA AT STANDARD	456	ern	VELOCITY	MOISTURE		MOISTURE		
CONDITIONS:	FLOW (DRY STD. FT ³ /MIN)		(FT/SEC)	(GRAINS/FT³)			(PERCENT)	
	400					·		
→ 8. AIR CONTAMINANTS	423	AC	TUAL EMISSIONS	L	I		<u></u>	
W AIR CONTAININANTS	EMISSIONS		CONCENTRATION	AVG.	EMISSIONS*	CONTROL	CONTROL	
	AVERAGE	MAXIMUM		(TONS/YR)	EST. METHOD	DEVICES*	EFFICIENCY%	
PARTICULATES	0.15	0.18	**	0.05	3			
SULFUR	0.13	V.10	***	0.03	3			
DIOXIDE	0.14	0.17		0.04	3			
CARBON MONOXIDE	0.47	0.56	PPM	0.14	3			
ORGANIC	V.T1	0/0	PPM	5.,77			—	
COMPOUNDS	0.18	0.21	N70.4	0.05	3			
NITROGEN OXIDES	2.17	2.60	PPM	0.65	3			
FLUORIDES								
OTITIO (ONTO INT)	A	A1		<0.01			_	
OTHER(SPECIFY)	Above emissions	Above emissions		Emissions above based on 500hrs/yr	Above based on SCC 20200102			
	based on	based on full		and full standby.	355 25250102			
	full prime	standby	ĺ		1	Į.		

9,	CHECK TYPES OF MONITORING AND RECORDING INSTRUMENTS THAT ARE ATTACHED:	
	OPACITY MONITOR (), SO2 MONITOR (), NOX MONITOR (), OTHER (SPECIFY IN COMMENTS) (X)	
10.	COMMENTS	
Hou	r meter	
	_	
	SIGNATURE	TO 4 0000
11.		DATE
	January January January	4/30/2010
	hu Khal / Val	4/30/2010

* REFER TO THE BACK OF THE PERMIT APPLICATION FORM FOR ESTIMATION METHOD AND CONTROL DEVICE CODES.

** EXIT GAS PARTICULATE CONCENTRATION UNITS: PROCESS — GRAINS/DRY STANDARD FT3 (70°F); WOOD FIRED BOILERS —
GRAINS/DRY STANDARD FT3 (70°F); ALL OTHER BOILERS — LBS/MILLION BTU HEAT INPUT.

*** EXIT GAS SULFUR DIOXIDE CONCENTRATIONS UNITS: PROCESS — PPM BY VOLUME, DRY BASES; BOILERS — LBS/MILLION BTU HEAT INPUT.

KOHLER POWER SYSTEMS


208-600 V

Diesel



Ratings Range

		OU MZ
Standby:	kW	37-50
_	kVA	37-63
Prime:	kW	33-45
	kVA	33~56



Generator Set Ratings

				130°C Standby	–	105°C Rise Prime Rating		
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps	
	120/208	3	60	47/59	163	43/54	149	
	127/220	3	60	49/61	161	45/56	148	
	120/240	3	60	47/59	141	43/54	129	
407	120/240	1	60	37/37	154	33/33	138	
4P7	139/240	3	60	50/63	150	45/56	135	
	220/380	3	60	40/50	76	36/45	68	
	277/480	3	60	50/63	75	45/56	68	
	347/600	3	60	40/50	48	36/45	43	
	120/208	3	60	50/63	173	45/56	156	
	127/220	3	60	50/63	164	45/56	148	
	120/240	3	60	50/63	150	45/56	135	
400	120/240	1	60	47/47	196	43/43	179	
4P8	139/240	3	60	50/63	150	45/56	135	
	220/380	3	60	50/63	95	45/56	85	
	277/480	3	60	50/63	75	45/56	68	
	347/600	3	60	50/63	60	45/56	54	
4Q10	120/240	1	60	50/50	208	45/45	188	

Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
- The generator set and its components are prototype-tested, factory-built, and production-tested.
- The 60 Hz generator set offers a UL 2200 listing.
- The generator set accepts rated load in one step.
- The 60 Hz generator set meets NFPA 110, Level 1, when equipped with the necessary accessories and installed per NFPA standards.
- The generator set complies with ISO 8528-5, Class G2, requirements for transient performance in all generator set configurations. Select the Decision-Maker[®] 550 controller for improved voltage regulation and ISO 8528-5, Class G3, compliance.
- The 60 Hz generator set engine is certified by the Environmental Protection Agency (EPA) to conform to Tier 3 nonroad emissions regulations.
- A one-year limited warranty covers all systems and components. Two-, five-, and ten-year extended warranties are also available.
- Alternator features:
 - The unique Fast-Response[™] Il excitation system delivers excellent voltage response and short-circuit capability using a permanent magnet (PM)-excited alternator.
 - The brushless, rotating-field alternator has broadrange reconnectability.
- Other features:
 - Controllers are available for all applications. See controller features inside.
 - The low coolant level shutdown prevents overheating (standard on radiator models only).
 - Integral vibration isolation eliminates the need for under-unit vibration spring isolators.

RATINGS: All three-phase units are rated at 0.8 power factor. All single-phase units are rated at 1.0 power factor. Standby Ratings: Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. Ratings are in accordance with ISO-3046/1, BS 5514, AS 2789, and DIN 6271. Prime Power Ratings: Prime power ratings apply to installations where utility power is unavailable or unreliable. At varying load, the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-8528/1, overload power in accordance with ISO-3048/1, BS 5514, AS 2789, and DIN 6271. For limited running time and base load ratings, consult the factory. Obtain the technical information bulletin (TIB-101) on ratings guidelines for the complete ratings definitions. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever. GENERAL GUIDELINES FOR DERATION: Altitude: Derate 0.5% per 100 m (328 ft.) elevation above 2300 m (7546 ft.). Temperature: Derate 2.0% per 10°C (18°F) temperature above 25°C (77°F).

Alternator Specifications

Specifications	Alternator			
Manufacturer	Kohler			
Туре	4-Pole, Rotating-Field			
Exciter type	Brushless, Permanent-Magnet			
Leads: quantity, type	12, Reconnectable			
Voltage regulator	Solid State, Volts/Hz			
Insulation:	NEMA MG1			
Material	Class H			
Temperature rise	130°C, Standby			
Bearing: quantity, type	1, Sealed			
Coupling	Flexible Disc			
Amortisseur windings	Full			
Voltage regulation, no-load to full-load				
Permanent magnet (PM) alternator	±2% Average			
550 controller (with 0.5% drift				
due to temperature variation)	3-Phase Sensing, ±0.25%			
One-step load acceptance	100% of Rating			
Unbalanced load capability	100% of Rated Standby Current			
Peak motor starting kVA:	(35% dip for voltages below)			
480 V 4P7 (12 lead)	194			
480 V 4P8 (12 lead)	212			

155

- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- · Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Vacuum-impregnated windings with fungus-resistant epoxy varnish for dependability and long life.
- Superior voltage waveform from a two-thirds pitch stator and skewed rotor.
- Fast-Response™ II brushless alternator with brushless exciter for excellent load response.

Application Data

F	na	i	n	e
-	им	и		•

240 V

4Q10 (4 lead)

Engine	
Engine Specifications	
Manufacturer	John Deere
Engine model	4024HF285B
Engine type	4-Cycle, Turbocharged
Cylinder arrangement	4 Inline
Displacement, L. (cu. in.)	2.4 (14 9)
Bore and stroke, mm (in.)	86 x 105 (3.39 x 4.13)
Compression ratio	18.2:1
Piston speed, m/min. (ft./min.)	375 (1230)
Main bearings: quantity, type	5, Replaceable Insert
Rated rpm	1800
Max. power at rated rpm, kWm (BHP)	60 (80)
Cylinder head material	Cast Iron
Crankshaft material	Ductile Iron
Valve material:	
Intake	Chromium-Silicon Steel
Exhaust	Stainless Steel
Governor: type, make/model	JDEC Electronic, Level 18, EUP
Frequency regulation, no-load to full-load	Isachronous
Frequency regulation, steady state	±0.25%
Frequency	Fixed
Air cleaner type, all models	Dry

Exhaust

Exhaust System	
Exhaust manifold type	Dry
Exhaust flow at rated kW, m ³ /min. (cfm)	12.0 (423)
Exhaust temperature at rated kW, dry exhaust, °C (°F)	574 (1066)
Maximum allowable back pressure, kPa (in. Hg)	7.5 (2.2)
Exhaust outlet size at engine hookup, mm (in.)	63.5 (2.5)

Engine Electrical

Engine Electrical System	
Battery charging alternator:	
Ground (negative/positive)	Negative
Volts (DC)	12
Ampere rating	70
Starter motor rated voltage (DC)	12
Battery, recommended cold cranking amps (CCA):	
Quantity, CCA rating	One, 640
Battery voltage (DC)	12

Fuel

Fuel System	
Fuel supply line, min. ID, mm (in.)	11.0 (0.44)
Fuel return line, min. ID, mm (in.)	6.0 (0.25)
Max. lift, engine-driven fuel pump, m (ft.)	3.0 (10.0)
Max. fuel flow, Lph (gph)	82 (21.7)
Fuel prime pump	Manual
Fuel filter	
Secondary	5 Microns @ 98% Efficiency
Water Separator	Yes
Recommended fuel	#2 Diesel

Lubrication

Lubricating System		
Туре	Full Pressure	
Oil pan capacity, L (qt.)	7.3 (7.7)	
Oil pan capacity with filter, L (qt.)	8.2 (8.7)	
Oil filter: quantity, type	1, Cartridge	
Oil cooler	Water-Cooled	

Application Data

Cooling

Radiator System	
Ambient temperature, °C (°F)*	50 (122)
Engine jacket water capacity, L (gal.)	2.6 (0.7)
Radiator system capacity, including engine, L (gal.)	10.6 (2.8)
Engine jacket water flow, Lpm (gpm)	98 (26)
Heat rejected to cooling water at rated kW, dry exhaust, kW (Btu/min.)	35.7 (2030)
Heat rejected to air charge cooler at rated kW, dry exhaust, kW (Btu/min.)	10.9 (621)
Water pump type	Centrifugal
Fan diameter, including blades, mm (in.)	597 (23.5)
Fan, kWm (HP)	2.9 (3.9)
Max. restriction of cooling air, intake and discharge side of radiator, kPa (in. H ₂ O)	0.125 (0.5)

^{*} Enclosure reduces ambient temperature capability by 5°C (9°F).


Operation Requirements

Air Requirements	
Radiator-cooled cooling air, m³/min. (scfm)≑	96 (3400)
Combustion air, m³/min. (cfm)	4.3 (152)
Heat rejected to ambient air:	
Engine, kW (Btu/min.)	14.0 (747)
Alternator, kW (Btu/min.)	7.6 (435)

Air density = 1.20 kg/m³ (0.075 lbm/ft³)

Fuel Consumption		
Diesel, Lph (gph) at % load	Standby	Rating
100%	16.2	(4.3)
75%	12.1	(3.2)
50%	8.5	(2.2)
25%	5.0	(1.3)
Diesel, Lph (gph) at % load	Prime	Rating
100%	13.7	(3.6)
75%	10.8	(2.9)
50%	7.6	(2.0)
25%	4.5	(1.2)


Controllers



Decision-Maker® 550 Controller

Audiovisual annunciation with NFPA 110 Level 1 capability. Programmable microprocessor logic and digital display features. Alternator safeguard circuit protection.

12- or 24-volt engine electrical system capability. Remote start, remote annunciation, and remote communication options. Refer to G6-46 for additional controller features and accessories.



Decision-Maker® 3+, 16-Light Controller

Audiovisual annunciation with NFPA 110 Level 1 capability. Microprocessor logic, AC meters, and engine gauge features. 12- or 24-volt engine electrical system capability. Remote start, prime power, and remote annunciation options. Refer to G6-30 for additional controller features and accessories.

KOHLER CO., Kohler, Wisconsin 53044 USA Phone 920-565-3381, Fax 920-459-1646 For the nearest sales and service outlet in the US and Canada, phone 1-800-544-2444 KohlerPower.com Kohler Power Systems Asia Pacific Headquarters 7 Jurong Pier Road Singapore 619159 Phone (65) 6264-6422, Fax (65) 6264-6455

Additional Standard Alternator Protection (standard Battery Rack and Cables Oil Drain and Coolant Drain Oil Drain Extension (with na Operation and Installation Li Radiator Drain Extension (w	ard with 550 controller) w/Hose Barb rrow skid and enclosure models only) terature	Remote Spee	pp Compensator d Adjust Control/Electronic Governor t Control lator Relocation
Available Options Approvals and Listings CSA Approval IBC Selsmic Certification UL2200 Listing Enclosed Unit Sound Enclosure (with en Weather Enclosure (with en Open Unit Exhaust Silencer, Critical Exhaust Silencer, Hospita	enclosed critical silencer) (kit: PA-324470) (kit: GM32386-KP1)	Air Cleaner R	estriction Indicator case Vent (oil and coolant) Added Factor Testing Is
Flexible Exhaust Connect Fuel System Auxiliary Fuel Pump Flexible Fuel Lines Fuel Pressure Gauge Subbase Fuel Tanks Controller Common Failure Relay	or, Staintess Steel	2-Year Basic 2-Year Prime 5-Year Basic 5-Year Compi 10-Year Major Other Option	r Components
	(16 light controller only) controller only) el	Dimensions a Overall Size, L x V Wide Skid: Narrow Skid: Welght (radiator r	
 □ Remote Mounting Cable □ Run Relay Cooling System □ Block Heater; Recommen Below 0°C (32°F) □ Radiator Duct Flange Electrical System 	ded for Ambient Temperatures		
			provided for reference only and should not be used for planning ur local distributor for more detailed information. DBY: